



Product Service

CERTIFICATE

No. Z2 096895 0013 Rev. 00

Holder of Certificate: **Olive Green Energy Co.,Ltd**
Building 1, No.188 Chuangye Road
Tongyuan Town, Haiyan County
314306 Jiaxing City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062366001-00

Valid until: 2028-10-12

Date, 2023-11-20

(Zhulin Zhang)



CERTIFICATE

No. Z2 096895 0013 Rev. 00

Model(s):

182 cell modules
 OLV-xxx-72M-DEAH (xxx=530 to 560 in step of 5)
 OLV-xxx-66M-DEAH (xxx=485 to 510 in step of 5)
 OLV-xxx-60M-DEAH (xxx=435 to 465 in step of 5)
 OLV-xxx-54M-DEAH (xxx=395 to 420 in step of 5)
 OLV-xxx-72N-DEGH (xxx=570 to 590 in step of 5)
 OLV-xxx-66N-DEGH (xxx=520 to 545 in step of 5)
 OLV-xxx-60N-DEGH (xxx=470 to 495 in step of 5)
 OLV-xxx-54N-DEGH (xxx=420 to 445 in step of 5)
 xxx stands for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

**Tested
according to:**

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016